



**CITY OF SAN MARCOS  
STANDARD PRODUCTS LIST**

SPL No. WW-65A

Sheet 1 of 1

for

**POLYETHYLENE TUBING FOR RECLAIMED WATER SERVICES**

**ISSUED: 01/01/2020**

**REVISED: \_\_/\_\_/\_\_**

**DESCRIPTION:** Tubing, polyethylene, meeting ASTM D 2737, CTS-OD, 1", made of PE 4710, minimum Pressure Class 250 psi (SDR-9), solid purple wall or purple shell over clear or blue core, with contrasting-color heat-indented printline. Only compression fittings recommended by the manufacturer used with stainless steel insert stiffeners may be used. Must have a 10 AWG Standard Copper tracer wire with HDPE Insulation.

APPROVAL DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT
01/01/20	ENDOT INDUSTRIES, INC. 60 Green Pond Road Rockaway, NJ 07866	EndoTrace PE 4710 (ASTM D2737)

**NOTE:**

- 1.
- 2.
- 3.
- 4.
- 5.